

# Commonwealth of Australia

Published by the Commonwealth of Australia





# **Australian Government**

#### **OZONE PROTECTION AND SYNTHETIC GREENHOUSE GAS MANAGEMENT ACT 1989**

# **GRANT OF EXEMPTION UNDER SECTION 40**

# EXEMPTION No. \$40E20753535

# THIS EXEMPTION IS IN FORCE DURING THE PERIOD

# COMMENCING 9 March 2014 and ENDING ON 8 March 2016

I, **Mr Matthew Dadswell, Assistant Secretary Environment Standards Branch**, Department of the Environment, delegate of the Minister, grant under subsection 40(3) of the *Ozone Protection and Synthetic Greenhouse Gas Management Act 1989*(Cth) (the **Act**) an Exemption under Section 40 (S40E) of the Act to:

National Jet Systems Pty Ltd (the Exemption Holder)

to:

#### Import halon fire protection equipment

This exemption is granted subject to the following conditions:

- 1. The exemption holder must notify the Department of Sustainability, Environment, Water, Population and Communities of a change of address or any other contact details, within 30 days of the change occurring.
- 2. The exemption holder must not permit the exemption number to be used by another person or business.
- 3. This exemption relates solely to the prohibition set out in clause 6 in Schedule 4, of the Act and the products to be imported must be:
  - a. halon fire protection equipment installed or for use in aircraft and essential for aircraft operation; or

- b. imported as replacements for either equivalent equipment exported for servicing or for equipment discharged in service.
- 4. The exemption holder must not cause the halon fire protection equipment to be discharged during training exercises.<sup>1</sup>
- 5. The halon products must not be surplus to the minimum requirements for operation of aircraft in line with Civil Aviation Safety Regulations 1988.

MM

Delegate of the Minister

#### 14 August 2014

<sup>1.</sup> Under subsection 45B(3) of the Act the use of halon fire protection equipment during a training exercise is treated as not being used for its designed purpose.