

# Fuel Quality Standards (Biodiesel) Determination 2025

I, Chris Bowen, Minister for Climate Change and Energy, make the following determination.

Dated 16/02/2025

Chris Bowen Minister for Climate Change and Energy



# 1 Name 1 2 Commencement 1 3 Authority 1 4 Definitions 1 5 Schedules 2 6 Fuel standard for biodiesel 2 Schedule 1—Repeals Fuel Quality Standards (Biodiesel) Determination 2019 3



### 1 Name

This instrument is the Fuel Quality Standards (Biodiesel) Determination 2025.

### 2 Commencement

(1) Each provision of this instrument specified in column 1 of the table commences, or is taken to have commenced, in accordance with column 2 of the table. Any other statement in column 2 has effect according to its terms.

Commencement information				
Column 1	Column 2	Column 3		
Provisions	Commencement	Date/Details		
1. The whole of this instrument	The day after this instrument is registered.			

Note:

This table relates only to the provisions of this instrument as originally made. It will not be amended to deal with any later amendments of this instrument.

(2) Any information in column 3 of the table is not part of this instrument. Information may be inserted in this column, or information in it may be edited, in any published version of this instrument.

### 3 Authority

This instrument is made under section 21 of the *Fuel Quality Standards Act* 2000.

### 4 Definitions

Note:

A number of expressions used in this instrument are defined in section 4 of the *Fuel Quality Standards Act 2000*, including fuel.

In this instrument:

**ASTM** followed by an alphanumeric code means the testing method developed under that code by the standards development organisation called ASTM International.

**biodiesel** means a diesel fuel obtained by esterification of oil derived from plants or animals.

**EN** followed by a numeric code means the testing method developed under that code by the European Committee for Standardization.

**mg/kg** means milligrams per kilogram, and is equivalent to 'parts per million' or 'ppm' by mass.

% m/m means per cent mass by mass, and is equivalent to 'mass %', '% mass' and 'weight %'.

% v/v means per cent volume by volume, and is equivalent to 'volume %', 'vol %' and '% vol'.

### 5 Schedules

Each instrument that is specified in a Schedule to this instrument is amended or repealed as set out in the applicable items in the Schedule concerned, and any other item in a Schedule to this instrument has effect according to its terms.

### 6 Fuel standard for biodiesel

- (1) In relation to a parameter mentioned in an item of the following table, biodiesel must comply with the specification for that parameter mentioned in that item.
- (2) For subsection (1), compliance with the specification for a parameter is determined by using the testing method for that parameter mentioned in that item of the table.

Fuel s	Fuel standard for biodiesel				
Item	Parameter	Specification	<b>Testing Method</b>		
1	Acid value	0.50 mg KOH/g maximum	ASTM D664		
2	Carbon residue—10% distillation residue	0.30% m/m maximum	ASTM D4530		
_3	Cold soak filterability	360 seconds maximum	ASTM D7501		
4	Copper corrosion—3 h at 50°C	Class 1 maximum	ASTM D130		
_5	Density at 15°C	$860-900 \text{ kg/m}^3$	ASTM D1298		
6	Derived cetane number	51.0 minimum	ASTM D6890		
7	Distillation—T90	360°C maximum	ASTM D1160		
8	Ester content	96.5% m/m minimum	EN 14103		
9	Flash point	120.0°C minimum	ASTM D93		
_10	Glycerides—monoglycerides	0.7% m/m maximum	ASTM D6584		
_11	Glycerides—diglycerides	0.2% m/m maximum	ASTM D6584		
_12	Glycerides—triglycerides	0.2% m/m maximum	ASTM D6584		
13	Glycerol—free	0.020% m/m maximum	ASTM D6584		
_14	Glycerol—total	0.250% m/m maximum	ASTM D6584		
_15	Kinematic viscosity at 40°C	$3.5-5.0 \text{ mm}^2/\text{s}$	ASTM D445		
16	Metals—Group I—Na, K	5 mg/kg maximum	EN 14538		
17	Metals—Group II—Ca, Mg	5 mg/kg maximum	EN 14538		
18	Methanol	0.20% m/m maximum	EN 14110		
19	Oxidation stability at 110°C	8.0 hours minimum	EN 14112		
20	Phosphorus	4.0 mg/kg maximum	EN 14107		
21	Sulfated ash	0.020% m/m maximum	ASTM D874		
22	Sulfur	10 mg/kg maximum	ASTM D5453		
23	Total contamination	24 mg/kg maximum	EN 12662		
24	Water	500 mg/kg maximum	ASTM D6304		

# Schedule 1—Repeals

## Fuel Quality Standards (Biodiesel) Determination 2019

1 The whole of the instrument

Repeal the instrument.